



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

398 East Dania Beach Blvd.
Suite 338
Dania Beach, FL 33004
954.399.8478 PH
954.744.4738 FX
contact@buildingdrops.com

Product Evaluation Report

of

Croft, LLC.

**“Series 30 Single Hung Window”
(Non-Impact) (Non-HVHZ)**

for

Florida Product Approval

FL# FL28797

Report No. 6084

Current Florida Building Code

Method: 1 – A (Certificate Method)
Category: Windows
Sub – Category: Single Hung

Product: *Series 30 Single Hung Window*
Material: *PVC*
Product Dimensions: *Refer to the installation detail, CRF019*

Prepared For:

Croft, LLC.
P.O. Box 826
McComb, MS 39649

Prepared by:


Hermes F. Norero, P.E.

Florida Professional Engineer # 73778

Date: 01/04/2019

Contents:

Evaluation Report Pages 1 – 3



Hermes F. Norero, P.E.
Florida No. 73778



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL#: FL58797

Date: 01/04/2019

Report No: 6084

Manufacturer: Croft, LLC.

Product Category: Windows

Product Sub-Category: Single Hung

Compliance Method: State Product Approval Method (1)(a)

Product Name: Series 30 Single Hung Window

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **Croft, LLC.** based on Method 1a of the State of Florida Product Approval, Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the Current Florida Building Code.

See Installation Instructions **CRF019**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the Current Florida Building Code, excluding the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the Current Florida Building Code and does require an impact resistant covering.
4. Site conditions that deviate from the details of drawing **CRF019** require further engineering analysis by a licensed engineer or registered architect.
5. See Installation Instructions **CRF019** for size and design pressure limitations.



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL#: FL58797

Date: 01/04/2019

Report No: 6084

Certification Agency: The manufacturer has demonstrated compliance of window products in accordance with the Current Florida Building Code and for manufacturing under an approved certification agency through **American Architectural Manufacturers Association** (FBC Organization #: CER1498).

Performance Standards: The product described herein has been tested per:

- AAMA/WDMA/CSA 101/I.S.2/A440-08

Referenced Data:

1. Product Testing performed by **Architectural Testing**
Report #: B9751.01-801-47, Report Date: 06/07/2012
2. Certification Agency
American Architectural Manufacturers Association
(FBC Organization #: CER1498)

Installation:

Refer to installation instructions (**CRF019**) for anchor spacing and more details of the installation requirements.

Design Pressure:

Refer to installation instructions (**CRF019**) for Design Pressures with respect to product sizes.