

398 East Dania Beach Blvd.
Suite 338
Dania Beach, FL 33004
954.399.8478 PH
954.744.4738 FX
contact@buildingdrops.com

Product Evaluation Report

of

Croft, LLC.

"Series 30 Picture Window"

(Non-Impact) (Non-HVHZ)

for

Florida Product Approval

FL# FL28821

Report No. 6090

Current Florida Building Code

Method: 1 – A (Certificate Method)

Category: Windows

Sub – Category: Fixed Window

Product: Series 30 Picture Window

Material: PVC

Product Dimensions: Refer to the installation detail, CRF020

Prepared For:

Croft, LLC. P.O. Box 826 McComb, MS 39649

Prepared by:

Hermes F. Norero, P.E.

Florida Professional Engineer # 73778 Date: 01/10/2019

Contents:

Evaluation Report Pages 1 – 3



FL#: FL28821 Date: 01/10/2019 Report No: 6090

Manufacturer: Croft, LLC.

Product Category: Windows

Product Sub-Category: Fixed Window

Compliance Method: State Product Approval Method (1)(a)

Product Name: Series 30 Picture Window

Scope:

This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **Croft, LLC.** based on <u>Method 1a</u> of the State of Florida Product Approval, Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the Current Florida Building Code.

See Installation Instructions **CRF020**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

- 1. This product has been evaluated and is in compliance with the Current Florida Building Code, excluding the "High Velocity Hurricane Zone" (HVHZ).
- 2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
- 3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the Current Florida Building Code and <u>does</u> require an impact resistant covering.
- 4. Site conditions that deviate from the details of drawing **CRF020** require further engineering analysis by a licensed engineer or registered architect.
- 5. See Installation Instructions **CRF020** for size and design pressure limitations.

FL#: FL28821 Date: 01/10/2019 Report No: 6090

Certification Agency: The manufacturer has demonstrated compliance of window products in accordance with the

Current Florida Building Code and for manufacturing under an approved certification agency through **American Architectural Manufacturers Association** (FBC Organization #: CER1498).

Performance Standards: The product described herein has been tested per:

AAMA/WDMA/CSA 101/I.S.2/A440-08

Referenced Data: 1. Product Testing performed by Architectural Testing

Report #: B9753.01-801-47, Report Date: 06/25/2012 Report #: C5721.01-801-47, Report Date: 02/19/2013

2. Certification Agency

American Architectural Manufacturers Association

(FBC Organization #: CER1498)

Installation:

Refer to installation instructions (**CRF020**) for anchor spacing and more details of the installation requirements.

Design Pressure:

Refer to installation instructions (CRF020) for Design Pressures with respect to product sizes.