

BUILDING DROPS

A Perfect Solution in Every Drop! Certificate of Authorization: 29578 398 East Dania Beach Blvd. Suite 338 Dania Beach, FL 33004 954.399.8478 PH 954.744.4738 FX contact@buildingdrops.com

Product Evaluation Report

of

Croft, LLC. "Series 60 Sliding Glass Door" (Non-Impact) (Non-HVHZ)

for

Florida Product Approval

FL# FL29195

Report No. 6171

Current Florida Building Code

Method: Category: Sub – Category: 1 – A (Certificate Method) Exterior Doors Sliding Exterior Door Assemblies

Product: Material: Product Dimensions: Series 60 Sliding Glass Door PVC Refer to the installation detail, CRF022

Prepared For:

Croft, LLC. P.O. Box 826 McComb, MS 39649

Prepared By: Hermes F. Norero, P.E. Florida Professional Engineer # 73778 Date: 03/07/2019 <u>Contents:</u> Evaluation Report Pages 1 – 3





Manufacturer:		Croft, LLC.		
Product Category:		Exterior Doors		
Product Sub-Category:		Sliding Exterior Door Assemblies		
Compliance Method:		State Product Approval Method (1)(a)		
Product Name:		Series 60 Sliding Glass Door (Non-Impact) (Non-HVHZ)		
Scope:	This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for Croft, LLC. based on <u>Method 1a</u> of the State of Florida Product Approval, Department of Business and Professional Regulation - Florida Building Commission.			
	Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.			
	This pr	has been evaluated for use in locations adhering to the Current Florida Building Code.		
	See Installation Instructions CRF022 , signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.			
Limits of Use:	1.	This product has been evaluated and is in compliance with the Current Florida Building Code, excluding the "High Velocity Hurricane Zone" (HVHZ).		

- 2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
- 3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the Current Florida Building Code and <u>does</u> require an impact resistant covering.
- 4. Site conditions that deviate from the details of drawing **CRF022** require further engineering analysis by a licensed engineer or registered architect.
- 5. See Installation Instructions **CRF022** for size and design pressure limitations.

Hermes F. Norero, P.E. Florida No. 73778 Page 2 of 3



Certification Agency:	Current Florid	turer has demonstrated compliance of window products in accordance with the da Building Code and for manufacturing under an approved certification agency erican Architectural Manufacturers Association (FBC Organization #: CER1498).	
Performance Standard	s: The product described herein has been tested per:		
	• A	AAMA/WDMA/CSA 101/I.S.2/A440-08	
Referenced Data:	1.	Product Testing performed by Architectural Testing Report #: C5716.01-801-47, Report Date: 02/20/2013	
	2.	Certification Agency American Architectural Manufacturers Association (FBC Organization #: CER1498)	

Installation:

Refer to installation instructions (**CRF022**) for anchor spacing and more details of the installation requirements.

Design Pressure:

Refer to installation instructions (CRF022) for Design Pressures with respect to product sizes.