

**NATIONAL CERTIFIED TESTING LABORATORIES**

8350 PARKLINE BLVD/SUITE 320 • ORLANDO, FL 32809
PHONE (407) 240-1356 FAX (407) 240-8882

Tuesday, February 21, 2006

To Whom It May Concern:

The standard test method used for structural loads in TAS 202 is ASTM E330. The minimum duration of a load in TAS 202 is 30 seconds. In Secure Enterprises report number NCTL-210-2064-1S the loads were held for 60 seconds which is double the amount required by TAS 202. This information was not recorded in the original report but can be verified by our paperwork and video recordings.

Sincerely,

Chris Bennett

Division Manager

National Certified Testing Laboratories

CB/mjt