

**EVALUATION REPORT OF  
UNION CORRUGATING COMPANY  
'29 GA. 5V PANEL'**


**FLORIDA BUILDING CODE 5<sup>TH</sup> EDITION (2014)  
FLORIDA PRODUCT APPROVAL  
FL 7271.3-R3  
ROOFING  
METAL ROOFING**

**Prepared For:  
Union Corrugating Company  
P. O. Box 229  
Fayetteville, NC 28302  
Telephone: (910) 483-0479  
Fax: (910) 483-8897**

**Prepared By:  
Bala Sockalingam, Ph.D., P.E.  
Florida Professional Engineer #62240  
1216 N Lansing Ave., Suite C  
Tulsa, OK 74106  
Telephone: (918) 492-5992  
FAX: (866) 366-1543**

**This report consists of  
Evaluation Report (2 Pages including cover)  
Installation Details (2 Pages)**

**Report No. C1999-11  
Date: 3.20.15**



Manufacturer:	Union Corrugating Company
Product Name:	5V Panel
Panel Description:	24" wide coverage with (5) 1/2" high ribs
Materials:	Minimum 29 ga., 80 ksi steel. Galvanized coated steel (ASTM A653) or Galvalume coated steel (ASTM A792) or painted steel (ASTM A755).
Deck Description:	Min 15/32" thick APA rated plywood or 7/16" thick OSB or min. 3/4" thick wood plank (min SG of 0.42) for new and existing constructions. Designed by others and installed as per FBC 2014.
Underlayment:	Minimum underlayment as per FBC 2014 Section 1507.4.5.1
Slope:	1/2:12 or greater in accordance with FBC 2014 Section 1507.4.2
Design Uplift Pressure: (Factor of Safety = 2)	52.5 psf @ fastener spacing of 12" o.c.
Panel Attachment: At panel ends At interior	#9-15 or #10-14 x 1.5" wood screw with washer @ max 6" o.c. across panel width through panel flat @ max 12" o.c. across panel width through panel flat
Test Standards:	Roof assembly tested in accordance with UL580-94 'Uplift Resistance of Roof Assemblies' and FM 4470 Section 5.5 'Resistance to Foot Traffic'.
Code Compliance:	The product described herein has demonstrated compliance with FBC 2014 Section 1507.4
Product Limitations:	Design wind loads shall be determined for each project in accordance with FBC 2014 Section 1609 or ASCE 7-10 using allowable stress design. The maximum fastener spacing listed herein shall not be exceeded. This product is not approved for use in the High Velocity Hurricane Zone. Fire classification is not within scope of this Evaluation Report. Refer to FBC 2014 Section 1505 and current approved roofing materials directory or ASTM E108/UL790 report from an accredited laboratory for fire ratings of this product.
Supporting Documents:	UL580 Roof Deck Construction No. 579  FM 4470 Test Report ENCON Technology Inc C1583-3, Reporting Date 7/24/08



## Construction No. 579 TGKX.579 Roof Deck Constructions

[Page Bottom](#)

### Design/System/Construction/Assembly Usage Disclaimer

- Authorities Having Jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Certified products, equipment, system, devices, and materials.
- Authorities Having Jurisdiction should be consulted before construction.
- Fire resistance assemblies and products are developed by the design submitter and have been investigated by UL for compliance with applicable requirements. The published information cannot always address every construction nuance encountered in the field.
- When field issues arise, it is recommended the first contact for assistance be the technical service staff provided by the product manufacturer noted for the design. Users of fire resistance assemblies are advised to consult the general Guide Information for each product category and each group of assemblies. The Guide Information includes specifics concerning alternate materials and alternate methods of construction.
- Only products which bear UL's Mark are considered Certified.

### Roof Deck Constructions


[See General Information for Roof Deck Constructions](#)

## Construction No. 579

October 23, 2012

**Uplift — Class 90**

**Fire Not Investigated**



1. **Metal Roof Deck Panels\*** — No. 29 MSG min thick coated steel. 24 in. cover width (26 in. overall width).

**AMERICAN CONSTRUCTION METALS** ([View Classification](#)) — "5V Crimp"

**MARLYN METALS INC** ([View Classification](#)) — "5V CRIMP"

**METAL SALES MANUFACTURING CORPORATION** ([View Classification](#)) — "5V-Crimp"

**UNION CORRUGATING CO** ([View Classification](#)) — "5-V"

2. **Fasteners (Screws)** — Fasteners to attach the plywood deck to the joists to be 2 in. long, No. 8 coarse thread screws. Fasteners to attach the panels to the deck to be No. 9-15 x 1-1/2 in. long sharp point screws with a hex-washer head or No. 10-14 x 1-1/2 in. hex-washer head wood screw with bonded neoprene washer. Fasteners to be spaced a maximum of 12 in. OC along one side of each rib.

3. **Deck** — Min 7/16 in. thick APA rated oriented strand board or min 15/32 in. thick, Type C-D, APA rated plywood.

4. **Underlayment** — 30 lb. felt, min 2 in. sidelap, attached per manufacturer's recommendations.

5. **Joists** — Graded dimension lumber, No. 2 or better. Spaced a max of 24 in. OC.

Refer to general information, Roof Deck Construction, for Items not evaluated.

\*Bearing the UL Classification Mark

Last Updated on 2012-10-23

---

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2015 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2015 UL LLC".