

L. Roberto Lomas P.E.

1432 Woodford Rd.
Clemmons, NC 27012
336-945-9695

Engineering Evaluation Report

Report No.: 510375

Manufacturer: Vista Window Company (C.I.)
3850 Elm Rd
Warren, OH 44483

Product Line: Series CP55W PVC Casement Picture Window – Impact resistant

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Community Affairs for Statewide Acceptance per Rule 9B-72.070 method 1(d). The product listed herein complies with the 2004 Florida Building Code with 2006 supplements.

Product description: Casement Picture Window, impact resistant made out of white rigid PVC with mitered and welded corners. Tested frame included flange and fin configurations.

Supporting Technical Documentation:

1. Approval document: drawing number FL 00293, dated 10/30/07 sheets 1 of 2, titled CP55W PVC Casement Picture Window, prepared, signed and sealed by L. Roberto Lomas P.E
2. Test report No.: 76906.04-501-47, signed by Corey A. Eisenhuth and Lynn Goerge
Architectural Testing Inc.
AAMA/WDMA/CSA 101/I.S.2/A440-05
Design pressure: ±50.0 psf
Water penetration resistance: 7.5 psf
3. Test report No.: 76398.02-501-44, signed by James P. Grippo and Lynn George
Architectural Testing Inc.
ASTM E1886-02 and ASTM E1996-02
ASTM E 1886/E 1996 Large Missile Impact test, Level D, Wind Zone 3
ASTM E 1886/E 1996 Cyclic Load Test, ±50 psf design pressure
4. Anchor calculations, report number 510376, prepared, signed and sealed by L. Roberto Lomas P.E.

Limitations and Conditions of use:


- Maximum design pressure: ±50 psf
- Maximum unit size: 48"x84"
- Maximum D.L.O.: 41 7/8"x77 3/4"
- Units must be glazed with 7/8" IGU consisting of: inboard lite 3/16" annealed – Air – laminated outboard lite consisting of 1/8" annealed – 0.090 Dupont SGP Interlayer – 1/8" annealed, per ASTM E 1300-02.
- This product is not rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection.
- Frame material to be white rigid PVC

Installation:

- Units must be installed in accordance with approval document, FL 00293.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas, P.E.
FL No.: 62514
11/19/2007