

R W Building Consultants, Inc.

Consulting and Engineering Services for the Building Industry

P.O. Box 230 Valrico, FL 33595 Phone 813.659.9197 Facsimile 813.659.4858

Florida Board of Professional Engineers Certificate of Authorization No. 9813

Product Evaluation Report

Report No.: FS 04-0331.01

Date: March 31, 2004

Product Category: Exterior Doors

Product sub-category: Swinging

Product Name: ULTRA 3'0 x 7'0 Single Outswing Door

Manufacturer: Dominion Building Products
6949 Fairbanks N. Houston
Houston, TX 7040
Phone: 713.466.6790

Scope: This is a Product Evaluation report issued by R W Building Consultants, Inc. and Wendell W. Haney, P.E. (System ID # 1993) for Dominion Building Products based on Rule Chapter No. 9B-72.070, Method 1d of the State of Florida Product Approval, Department of Community Affairs-Florida Building Commission.


RW Building Consultants and Wendell W. Haney, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the Florida Building Code (2001 Edition) and where pressure requirements, as determined by Chapter 16 of The Florida Building Code, do not exceed the following design pressures:

Design Pressure Rating:

Maximum Design Pressure Rating Positive 55.0 PSF Negative 55.0 PSF
(See Limitations for size restrictions)

See Drawing No.: FL-200 dated March 30, 2004 prepared by R W Building Consultants, Inc. and signed and sealed by Wendell W. Haney, P.E. (FL # 54158) for specific use parameters.



Supporting Documents

A Drawing

1. Drawing No. FL-200 titled Pre-Assembled Metal Door for Metal Buildings, sheets 1 through 4 of 4 prepared by R W Building Consultants, Inc. (Florida Board of Professional Engineers Certificate of Authorization No. 9813), dated March 30, 2004, with no revisions, signed and sealed by Wendell W. Haney, P.E.

B Test

1. Testing per ASTM E1886 & ASTM E1996/TAS 201 & 203 as performed by Hurricane Engineering & Testing Inc. and reported in test report number HETI-03-1285, dated January 21, 2003, signed by Rafael E. Droz-Seda, P.E.
2. Testing per ASTM E330-02 / PA 202-94 / TAS 202 as performed by Hurricane Engineering & Testing Inc. and reported in test report number HETI-03-1284, dated January 21, 2003, signed by Rafael E. Droz-Seda, P.E.
3. Testing per ASTM E 8-01 el. as performed by Hurricane Engineering & Testing Inc. and reported in test report number HETI-03-T020, dated January 16, 2003, signed by Rafael E. Droz-Seda, P.E.

C Calculations

1. Anchor analysis for loading conditions, prepared, signed and sealed by Wendell W. Haney, P.E.

D Other

1. Certificate of Participation issued by National Accreditation & Management Institute, Inc., certifying that Dominion Building Products is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53.
Dominion Building Products ID # D-587-1

