

- 1) SOIL COMPACTION
- C) STEEL FRAMING AND CONNECTIONS , (IF APPLICABLE WITH THE FINAL DESIGN OPTION)

(REFER TO ATTACHED COPY OF THE INSPECTION FORM)

\*\*\*\*\*  
 ADDITIONAL COMMENTS MAYBE PENDING AFTER REVIEW OF THE REQUESTED DOCUMENTS AS LISTED ABOVE

<b>Review Group: AUTO</b>			<b>REVIEW DATES</b>			
<b>Review Type</b>	<b>Status</b>	<b>Reviewer</b>	<b>Sent</b>	<b>Due</b>	<b>Received</b>	<b>Days Elapsed</b>
BUILDING	DENIED	MICHEL MESA	9/17/15	9/26/15	9/29/15	12
<b>Remarks and Notes:</b> (9/29/2015 2:47 PM MM) 1. MEETING WITH PROFESSIONAL OF RECORD REQUIRED BEFORE ANY ADDITIONAL PLAN REVIEW. 2. NEED DERM, FIRE, IMPACT FEE AND TRADE APPROVALS. 3. NEED TO SHOW CERTIFICATE OF AUTHORIZATION FOR FIRM ON TITTLE BLOCK AS PER 61G15 -23.002 AND/OR 61G1-16.004 (SIMJA CONSTRUCTION DESIGNERS AND BUILDERS) DESIGNER INFORMATION MISSING FROM TITTLE BLOCK, TITTLE BLOCK MUST COMPLY WITH FLORIDA STATUTES PREVIOUSLY CITED. 4. SHOW OCCUPANCY TYPE, CONSTRUCTION TYPE, AND OCCUPANCY LOAD AS PER FBC 107.3.5. 5. SHOW ACCESSIBILITY FROM SITE ARRIVAL POINT FBC 2010 ACC 202.6 ARCHITECTURAL BARRIER REMOVAL. 6. COORDINATE INDEX WITH PAGES SUBMITTED FBC 107.2. 7. UNITY OF TITTLE REQUIRED IF THESE 2 UNITS ARE TO BE COMBINED. 8. PROVIDE A CERTIFIED COPY OF THE LAST APPROVED PERMIT SHOWING ALL EXISTING CONDITIONS (ALL AREAS NOT SHOWN ON MICROFILM WILL HAVE TO COMPLY WITH FBC 2010 AND SHOW ON PLANS AS TO BE LEGALIZED, IF NOT SHOWN IT MUST COMPLY WITH FBC 2010 EXISTING). 9. PROVIDE VERTICAL ACCESSIBILITY AS PER FBC 2014 ACC CH 2. 10. NOT ENOUGH INFORMATION PROVIDED FOR A FULL REVIEW. TOO MANY COMMENTS TO LIST. FBC 2010 107.2.1 INFORMATION ON CONSTRUCTION DOCUMENTS. CONSTRUCTION DOCUMENTS SHALL BE DIMENSIONED AND DRAWN UPON SUITABLE MATERIAL. CONSTRUCTION DOCUMENTS SHALL BE OF SUFFICIENT CLARITY TO INDICATE THE LOCATION, NATURE AND EXTENT OF THE WORK PROPOSED AND SHOW IN DETAIL THAT IT WILL CONFORM TO THE PROVISIONS OF THIS CODE AND RELEVANT LAWS, ORDINANCES, RULES AND REGULATIONS, AS DETERMINED BY THE BUILDING OFFICIAL. (SEE ALSO SECTION 107.3.5). 11. DO NOT REMOVE VOID SHEETS. CLOUD-IN ALL CHANGES. PROVIDE RESPONSE SHEET ADDRESSING EACH OF THE COMMENTS AND INDICATE THE SHEET IN WHICH CORRECTION IS FOUND. 12. ADDITIONAL COMMENTS MAY BE PENDING AFTER REVIEW OF THE REQUESTED DOCUMENTS AS LISTED ABOVE.						
ELECTRICAL	DENIED	THOMAS FLINGOS	9/17/15	9/26/15	9/24/15	7
<b>Remarks and Notes:</b> (9/24/2015 12:32 PM TF) 1-PLEASE PROVIDE ELECTRICAL RISER AND PANEL INDEX FOR BOTH UNITS						
MECHANICAL	DENIED	ANDRES PEREZ	9/17/15	9/26/15	9/29/15	12
<b>Remarks and Notes:</b> (9/29/2015 9:17 AM AP) 1-Miami-Dade Fire approval req. 2-Show on plans equip. schedule (ditails) 3-Show on plan all CFM for each room 4-Return req. all rooms/areas w/doors 5-Show on plans location of outside condenser, must meet 175ph wind.						
PLAN CHECK	PROCESSED	LUIS GARCIA	9/17/15	9/28/15	9/17/15	0
<b>Remarks and Notes:</b>						