

December 13th, 2021

Mr. Robert A. Lash, Esq.
Attorney
Moody, Salzman, Lash, Locigno
2770 NW 43rd Street, Suite A
Gainesville, FL 32606-7419


Subject: **New St 765 SW 133rd Way**

I have reviewed the permit documents and truss shop drawings for the residence located at 765 SW 133rd Way in Newberry, Florida. Much of the roof based on these two documents has a 1 ¾:12 roof slope. These areas include the following:

- Garage Area – 1,114 square feet
- Master Bedroom Suite and Dining Room – 885 square feet
- Master Bedroom and Walk in Closet – 577 square feet

The balance of the roof areas should have a 2:12 roof slope if installed per the permit documents. Let me know if you have any questions.

Sincerely,



John H. Southard, M.S., P.E.
Southard Engineering, Inc.
President

This item has been electronically signed and sealed by John Southard, P.E. (FL PE 57599) on 13 December 2021 using a digital signature. Printed copies of this document are not considered signed and sealed. This digital signature must be verified on any electronic copies. Southard Engineering, Inc., 4566B NW 5th Blvd., Gainesville FL 32609 (FL CA 9195)

