

**From:** [Madani, Mo](#)  
**To:** [Madani, Mo](#)  
**Subject:** Fwd: Declaratory Statement  
**Date:** Wednesday, March 3, 2021 6:29:21 AM  
**Attachments:** [Trachte Building Systems \(DS 2021-006\).pdf](#)  
[ATT00001.htm](#)

---

Sent from my iPad

Begin forwarded message:

**From:** "Gascon, Jaime (RER)" <Jaime.Gascon@miamidade.gov>  
**Date:** March 2, 2021 at 4:57:32 PM EST  
**To:** "Madani, Mo" <Mo.Madani@myfloridalicense.com>  
**Cc:** "Makar, Helmy (RER)" <Helmy.Makar@miamidade.gov>, "Fernandez, Eduardo (RER)" <Eduardo.Fernandez2@miamidade.gov>  
**Subject:** RE: Declaratory Statement

**[NOTICE]** This message comes from a system outside of DBPR. Please exercise caution when clicking on links and/or providing sensitive information. If you have concerns, please contact your Knowledge Champion or the DBPR Helpdesk.

Good afternoon Mo,

Thank you for sharing this declaratory statement filing with us. The following comments are provided.

Section 2222.4.3 is intended to apply to a structure's envelope when constructed of single-skin steel. Single-skin steel claddings of less than 24 ga. can be defeated when undergoing forced entry testing requirements. Products tested to the TAS' must also comply with the provisions of the HVHZ for acceptance.

Therefore, the minimum gage steel of FBC-Building section 2222.4.3 must also be complied with when evaluating or certifying a single-skin steel garage door tested for TAS201, TAS202 and TAS203 for use in the HVHZ.

Contact us if you have any questions or if we can assist further.

Thank you.

**Jaime D. Gascon, P.E.**  
Director, Board and Code Administration Division  
**Miami-Dade County Department of Regulatory and Economic Resources**

11805 SW 26 St, Room 230  
Miami, FL 33175-2474  
Phone:(786) 315-2508

[www.miamidade.gov/building](http://www.miamidade.gov/building)

*Miami-Dade County is a public entity subject to Chapter 119 of the Florida Statutes concerning public records. Email messages are covered under such laws and thus subject to disclosure.*

---

**From:** Madani, Mo <Mo.Madani@myfloridalicense.com>

**Sent:** Tuesday, March 2, 2021 8:57 AM

**To:** Gascon, Jaime (RER) <Jaime.Gascon@miamidade.gov>; Makar, Helmy (RER) <Helmy.Makar@miamidade.gov>

**Subject:** Declaratory Statement

EMAIL RECEIVED FROM EXTERNAL SOURCE

Jaime/Helmy, please see attached request for Dec.

Thanks

Mo Madani, Technical Director  
Building Codes & Standards office  
2601 Blair Stone Road  
Tallahassee, Florida 32399  
850-717-1825