

ACCESSIBILITY ADVISORY COUNCIL

GROUNDS FOR APPROVAL

- **Economic Hardship**
 - Does the cost of providing vertical accessibility meet or exceed 20% of the cost of the alteration to the primary function area?
 - If the 20% threshold is met, the waiver SHALL be granted.
 - Does not apply to new construction.
 - Fit-outs/Build-outs are considered new construction
- **Historic Nature**
 - Has the applicant provided documentation of the historic significance of the building?
 - Would the historic significance of the structure be negatively impacted by the alterations applicant would have to make to provide accessibility?
 - Can be combined with Technical Infeasibility or Economic Hardship
- **Technical Infeasibility**
 - Is the structure built in a way that would otherwise place unnecessary, unreasonable, or extreme hardship on the applicant, if they were required to provide accessibility?
 - Has the applicant provided comments from a licensed design professional?
 - Would have to rebuild, demolish, encroach on property lines, etc.

ACCESSIBILITY ADVISORY COUNCIL

Kellogg Park Nature Center - WAV # 762

Issue: Vertical accessibility to the second floor.

Project Type: New construction

Project Progress: Under Construction

Project Description:

The applicant is requesting a waiver from providing vertical accessibility to the second floor of a proposed new building with a total floor area of 1,753 square feet. The second floor consists solely of a 100-square-foot observation deck and does not include any additional infrastructure, occupiable rooms, or functional program elements. The total estimated construction cost for the project is \$551,617.

According to the project architect, the second-floor space is intended exclusively as a passive observation area, providing a vantage point over the parking area. The space is not designed to support primary building functions, active use, or operational activities. All essential building functions, including fully ADA-compliant restrooms, are located on the first floor, which is fully accessible.

Further, the architect states that no required programmatic elements are located on the second floor, and access to this area is not necessary for public use or building operations. The architect also notes that the cost of installing a compliant lift would account for roughly 30% of the total building construction cost, representing a significant financial burden that offers no meaningful improvement to accessibility, as all primary functions are already located on the accessible first floor.

The applicant has submitted two cost estimates of \$138,980 and \$121,243 for a lift. The applicant alleges substantial financial costs will be incurred by the owner if the waiver is denied and the hardship is caused by a condition or set of conditions affecting the owner which does not affect owners in general.

Uploaded Documents:

1. Construction Cost
2. Cost Estimates for Compliance
3. Licensed Design Professional Comments
4. Plans/Pictures

STAFF RECOMMENDATION:

Staff recommends denying the request for waiver for vertical accessibility since the project in question is new construction.

Items to be waived:

ACCESSIBILITY ADVISORY COUNCIL

Vertical accessibility to the structure, as required by section 553.509, Florida Statutes.

553.509 Vertical accessibility. This part and the Americans with Disabilities Act Standards for Accessible Design do not relieve the owner of any building, structure, or facility governed by this part from the duty to provide vertical accessibility to all levels above and below the occupiable grade level, regardless of whether the standards require an elevator to be installed in such building, structure, or facility, except for:

- (a) Elevator pits, elevator penthouses, mechanical rooms, piping or equipment catwalks and automobile lubrication and maintenance pits and platforms;
 - (b) Unoccupiable spaces, such as rooms, enclosed spaces and storage spaces that are not designed for human occupancy, for public accommodations or for work areas; and
 - (c) Occupiable spaces and rooms that are not open to the public and that house no more than five persons, including, but not limited to equipment control rooms and projection booths.
 - (d) Theaters, concert halls, and stadiums, or other large assembly areas that have stadium-style seating or tiered seating if ss. 221 and 802 of the standards are met.
 - (e) All play and recreation areas if the requirements of chapter 10 of the standards are met.
 - (f) All employee areas as exempted in s. 203.9 of the standards.
 - (g) Facilities, sites, and spaces exempted by s. 203 of the standards.
- (2) However, buildings, structures, and facilities must, as a minimum, comply with the Americans with Disabilities Act Standards for Accessible Design.

206.2.4 Spaces and Elements. At least one accessible route shall connect accessible building or facility entrances with all accessible spaces and elements within the building or facility which are otherwise connected by a circulation path unless exempted by 206.2.3 Exceptions 1 through 7.

402.2 Components Accessible routes shall consist of one or more of the following components: Walking surfaces with a running slope not steeper than 1:20, doorways, ramps, curb ramps excluding the flared sides, elevators, and platform lifts. All components of an accessible route shall comply with the applicable requirements of Chapter 4 and 208.3.1.

Waiver Criteria: There is no specific guidance for a waiver of this requirement in the code. The Commission's current rule, authorized in Section 553.512, Florida Statutes, provides criteria for granting waivers and allows consideration of unnecessary or extreme hardship to the applicant if the specific requirements were imposed.

MOTIONS

- I move to recommend that the Florida Building Commission approve this request for waiver on the grounds of _____.
 - Economic Hardship
 - Historic Nature

ACCESSIBILITY ADVISORY COUNCIL

- Technical Infeasibility
- I move to recommend that the Florida Building Commission deny this application.
 - No rationale necessary.
- I move to recommend that the Florida Building Commission defer this request for waiver to the next meetings of the Council and the Commission for the purpose of allowing the applicant to _____:
 - Submit requested information
 - Contact building official or building department
 - Etc.