From: Holland, Bryan < Bryan. Holland@nema.org>

Sent: Monday, May 6, 2024 9:20 AM

To: Bigelow, Joe <Joe.Bigelow@myfloridalicense.com>
Cc: Madani, Mo <Mo.Madani@myfloridalicense.com>
Subject: RE: Upcoming Electrical TAC meeting availability



Good Morning Gentlemen,

In preparation for our ETAC meeting on Wednesday, I would like to share the following comments on the cost impact estimates for 2023 NEC changes:

- ➤ FR-9628 to 210.12(A) on page 376 is a bit of an issue for the TAC. The exemption sunsets on 1/1/25 well before the 2023 NEC will go into effect in Florida. However, the first draft of the 2026 NEC will make the exception permanent and extend the exception to dwelling garages and dwelling accessory buildings. If this first revision survives the second draft, a TIA will likely be issued to reflect this change in the 2023 NEC. The ETAC should have an open conversation on the impact of TIAs and how they should be incorporated in adoption of the 2023 NEC with the 9th edition FBC.
- > SR-8090 to 210.52(C) on page 378 will be a decrease in cost as NO receptacles will be required for island and peninsular countertops and work surfaces.
- ➤ FR-7870 to 314.24(C) on page 404 will not be an increase in cost as it only impacts the choice of boxes that can be used with side entries and the manufacturer of boxes that choose to include side entries. The code does not require the use of boxes with side entries.
- ➤ FR-7851 to 551.40(D) on page 450 was further modified by SR-8708 which now requires the listed grounding monitor interrupter to be installed by the RV manufacturer and not as a field-installable option so there is no direct installation cost.

Overall, I find the report to be rather comprehensive and well-done. The above items are not a deal-breaker, so I will be prepared to vote in approval of the report at conclusion of our meeting.

TAKE CARE,

Bryan

Bryan P. Holland, MCP, CStd.

Managing Director, Technical Field Representatives

- **** 972.358.0543
- <u>bryan.holland@nema.org</u>
- www.NEMA.org
- 1300 North 17th Street | Suite 900 | Arlington | VA | 22209