



Florida Building Codes

USER: Joe Bigelow, Department of Business & Professional Regulation, DBPR Personnel

[Binding Interpretations Menu](#) > [Petition Search](#) > [Petition List](#) > [Petition Detail](#) > **[Petition Comment Detail](#)**

OFFICE OF THE
SECRETARY

Petition #	228
Submitted By	Richard Schauland
Date Submitted	07/21/2021
Comment	The Building Official is authorized by 107.1 to require a registered design professional to draw up the plans to fix the violation. This is a common practice, especially in situations like the one described in this petition. Since the stucco was applied improperly and will most likely fail in the future causing damage to the structure, the best practice is to require a registered design professional to design the correction or remove the violation and start over.

[Back](#)

[DBPR Administration Menu](#)

[Contact Us](#) :: [2601 Blair Stone Road, Tallahassee FL 32399](#) Phone: 850-487-1824

The State of Florida is an AA/EEO employer. [Copyright 2007-2013 State of Florida.](#) :: [Privacy Statement](#) :: [Accessibility Statement](#) :: [Refund Statement](#)

Under Florida law, email addresses are public records. If you do not want your e-mail address released in response to a public-records request, do not send electronic mail to this entity. Instead, contact the office by phone or by traditional mail. If you have any questions, please contact 850.487.1395. *Pursuant to Section 455.275(1), Florida Statutes, effective October 1, 2012, licensees licensed under Chapter 455, F.S. must provide the Department with an email address if they have one. The emails provided may be used for official communication with the licensee. However email addresses are public record. If you do not wish to supply a personal address, please provide the Department with an email address which can be made available to the public. To determine if you are a licensee under Chapter 455, F.S., please click [here](#).

