

R403.7.1

Equipment Sizing

- Make sure that the total cooling capacity of all cooling equipment is at least equal to the calculated cooling design load, but not more than 1.15 times of that load.

