

Plan Review - Review Comments Report

Project Name: **BD24021528001**

REVIEW COMMENTS			
14	1	Building Miguel Lemus 11/12/24 2:23 PM	Library Comment (FBC-A201.1.1) < VERTICAL ACCESSIBILITY > Provide access to all levels, or provide an approved waiver from the State of Florida. Link to apply for waiver: https://www.floridabuilding.org/aw/accessibility_application_options.a spx