

## Final Exam

### Florida Building Code and Florida Statute Rules for Alarm Contractors

Question	Choice 1	Choice 2	Choice 3	Choice 4
The latest edition of the Florida Building Code is _____.	2017	2018	2019	2020
The Building Code is approved by the _____.	State Fire Marshal	electrical contractors licensing board	Governor	Florida Building Code Commission
The Florida Building Code is reissued every _____.	3 years	year	whenever necessary	every 10 years
The effective date of SB1140 is(was) _____.	July 1, 2022	January 1, 2023	January 1, 2022	Not yet signed into law
A fire alarm project with _____ initiating and notification devices is subject to a simplified permitting process	10 or less	Less than 50	20 or fewer	more than 100
Florida Statute _____ relates to the Florida Building Code	489 Part II	69A-48	Chapter 553 part IV	633
The section of Florida Statutes that relates to a uniform fire alarm permit application is _____.	489.518	489.100	533.7921	533.793
Adoption of electrical and alarm standards shall be the _____.	latest published edition	decided by the Governor	up to the Florida Building Commission	current edition
According to 553.885 carbon monoxide alarms are required _____.	in all new construction	within 10 feet of each room used for sleeping purposes	In every new building	in hospitals
According to 553.885, a carbon monoxide alarm must _____.	produce a distinct audible alarm	be hardwired	approved by the ECLB	last for 10 years or more