

## ACCESSIBILITY ADVISORY COUNCIL

April 7, 2003

\  
Amstar Stadium Cinemas – The applicant requested a waiver from providing vertical accessibility to all rows of seating in a 12 screen movie theater complex. The Council recommended approving the request provided additional wheelchair seating is provided in accordance with the Florida code; that all end row seats have removable arms and that no wheelchair seating is provided on the ends.

Sysco Food Service – The applicant requested a waiver from providing vertical accessibility to a mezzanine containing two offices, toilets and beverage storage. The Council recommended denying the request as no hardship was demonstrated.

Lebac, Inc. – The applicant requested a waiver from providing vertical accessibility to the second and third floors of a single family dwelling being converted to a bed and breakfast. The accessible first floor contains a dining room, toilet rooms and a food preparation area. It is an historic building and the Council recommended approval based on technical infeasibility since it would require demolition of an open staircase to install an elevator.

Trump International Golf Course – The applicant requested a waiver from providing an accessible path of travel from a public street to a club house in a private golf facility. The portion of the application pertaining to access to the club house from the parking area was withdrawn. The Council recommended granting the request based on technical infeasibility because of the slope of the terrain.