

DEPARTMENT OF COMMUNITY AFFAIRS

FLORIDA BUILDING COMMISSION

NOTICE IS HEREBY GIVEN that the Florida Building Commission has issued a Declaratory Statement in response to the request received from James E. Fowler, Jr., P.E., of National Engineering Corporation on March 26, 2004. It was assigned the number DCA04-DEC-072.

This Declaratory Statement was issued September 30, 2004. The Florida Building Commission interpreted Section 1003.5, Florida Building Code, Plumbing Volume, and found that this code provision pertains to both on-site sewage disposal systems and central municipal sewer systems and that an exception may be allowed for the size of grease interceptors. A copy of the Declaratory Statement may be obtained by writing: Paula P. Ford, Commission Clerk, Department of Community Affairs, 2555 Shumard Oak Boulevard, Tallahassee, Florida 32399-2100.