

DEPARTMENT OF COMMUNITY AFFAIRS

FLORIDA BUILDING COMMISSION

NOTICE IS HEREBY GIVEN that the Florida Building Commission has issued a Declaratory Statement in response to the request received from George A. Hegedus of Structural Systems, Inc. on May 12, 2004. It was assigned the number DCA04-DEC-109. This Declaratory Statement was issued September 30, 2004. The Florida Building Commission interpreted Section 1606.1.8, Florida Building Code, Building Volume, and found that the subject property is located outside of the coastal construction control line unless the property is located within 1500 feet of the mean high tide line. A copy of the Declaratory Statement may be obtained by writing: Paula P. Ford, Commission Clerk, Department of Community Affairs, 2555 Shumard Oak Boulevard, Tallahassee, Florida 32399-2100.