

DEPARTMENT OF COMMUNITY AFFAIRS

FLORIDA BUILDING COMMISSION

NOTICE IS HEREBY GIVEN that the Florida Building Commission has issued a Declaratory Statement in response to the request received from Palm Beach County - Building Division on May 12, 2004. It was assigned the number DCA04-DEC-110. This Declaratory Statement was issued September 30, 2004. The Florida Building Commission interpreted Section 706.3, Florida Building Code, Plumbing Volume, and found that this code provision does not prohibit offset closet flanges connecting a water closet and the sanitary drainage pipe when all pipe fittings meet applicable standards prescribed by the code. A copy of the Declaratory Statement may be obtained by writing: Paula P. Ford, Commission Clerk, Department of Community Affairs, 2555 Shumard Oak Boulevard, Tallahassee, Florida 32399-2100.