

DCA04-DEC-070 by Jimmy Worley, Ruffin Building Systems.

The petitioner request clarification relative to whether or not their product falls under any of the sub categories of Rule 9B-72.(the petitioner is a manufacturer of large metal buildings which consists of a specifically designed, integrated set of components and assemblies that function synergistically in the form of a complete building shell, which is governed the building code of jurisdiction and recognized design specifications published by the American Institute of Steel Construction AISC and the American Iron and Steel Institute ANSI).

Committee Recommendation:

The buildings in question are custom fabricated buildings in accordance with Section 553.842(11), Florida Statutes. Separate approval for individual buildings per Rule 9B-72 is not required. However, steel deck diaphragms, siding, sheathing, windows, doors, and other structural components listed in Rule 9B-72 are subject to the requirements of Rule 9B-72.