

**From:** Mike Silvers <Silvers@floridarooft.com>  
**Sent:** Wednesday, January 28, 2026 5:30 PM  
**To:** Madani, Mo <Mo.Madani@myfloridalicense.com>  
**Subject:** Comment on R11797 AS

**[NOTICE]** This message comes from a system outside of DBPR. Please exercise caution when clicking on links and/or providing sensitive information. If you have concerns, please contact your Knowledge Champion or the DBPR Helpdesk.

Mo,

Please note that the referenced modification below was submitted and approved for Building Chapter 15. Unfortunately, I missed submitting a correlative change for the Residential Subcode Chapter 9 which has identical language pre-modification. As you know we try to keep the Building and Residential roofing sections aligned to avoid confusion.

Modification 11797 as approved:

**1507.3.9 Flashing.**

*At the juncture of the roof ~~Interruptions, terminations and penetrations of the roof system~~ vertical surfaces, ~~f~~Flashing and/or counterflashing shall be ~~provided~~ installed in accordance with the manufacturer's installation instructions or the recommendations of the FRSA/TRI Florida High Wind Concrete and Clay Roof Tile Installation Manual, Seventh Edition where the basic wind speed,  $V_{asd}$ , is determined in accordance with Section 1609.3.1. was submitted for Building Chapter 15.*

I respectfully ask that the same change as shown below be made in the Residential Subcode as a correlative change.

**R905.3.8 Flashing.**

*At the juncture of roof ~~Interruptions, terminations and penetrations of the roof system~~ vertical surfaces, ~~f~~Flashing and/or counterflashing shall be ~~provided~~ installed in accordance with the manufacturer's installation instructions, recommendations of the FRSA/TRI Florida High Wind Concrete and Clay Roof Tile Installation Manual, Seventh Edition where the  $V_{asd}$  is determined in accordance with Section R301.2.1.3.*

My apologies.

Thanks,

**Mike Silvers, CPRC**

Director of Technical Services

FRSA, PO Box 4850, Winter Park, FL 32793

3855 N. Econlockhatchee Trail, Orlando, FL 32817

407-671-3772 ext. 169

[www.floridarooft.com](http://www.floridarooft.com)

*"FRSA-Florida's Association of Roofing Professionals"*



