

Mo Madani, Technical Director  
Building Codes & Standards Office  
2601 Blair Stone Road  
Tallahassee, Florida 32399  
850-717-1825

**From:** Skip Gregory <[gregoryskip@gmail.com](mailto:gregoryskip@gmail.com)>  
**Sent:** Friday, January 30, 2026 10:40 PM  
**To:** Madani, Mo <[Mo.Madani@myfloridalicense.com](mailto:Mo.Madani@myfloridalicense.com)>  
**Subject:** Comments on the FBC

Mo, I know I had to get this to you by 1/30/26 and it is 10:30 PM now so it is still legally 1/30/26. Truth is, I forgot to send this to you earlier in the day.  
There are only two items I found that really do need to be fixed and both are editorial.

Here they are:

**1. It is no longer titled the Guidelines but is now referenced in outpatient facilities as The Outpatient Code. See 452.2.2 of the revisions.**

Revise Section 451.3.16 to read as follows:

  **451.3.16** As required by *The Guidelines Outpatient Code*, a waste anesthetic gas disposal (WAGD) system, in accordance with NFPA 99, Health Care Facilities Code, shall be provided in operating rooms where nitrous oxide and/or inhalation ~~anesthsia~~ anesthesia gas is intended to be administered.

**SP-FBC-B – Ch.4 – Errata #1**