

TABLE C407.2(1)
REQUIREMENTS FOR SIMULATED BUILDING PERFORMANCE

SECTION^a	TITLE
Envelope	
C401.3	<i>Building thermal envelope certificate</i>
C402.2.1.1	Joints staggered
C402.2.1.2	Skylight curbs
C402.2.6	Insulation of radiant heating system panels
C402.6	Air leakage— <i>building thermal envelope</i>
Mechanical	
C403.1.1	Calculation of heating and cooling loads
C403.1.2	Data centers
C403.2	System design
C403.3	Heating and cooling equipment efficiencies
C403.4.1	Thermostatic controls
C403.4.2	Off-hour controls
C403.4.7	Heating and cooling system controls for operable openings to the outdoors
C403.5.5	Economizer fault detection and diagnostics
C403.7, except C403.7.4.1	Ventilation and exhaust systems
C403.8, except C403.8.6	Fan and fan controls
C403.9	Large-diameter ceiling fans
C403.12, except C403.12.3	Refrigeration equipment performance
C403.13	Construction of HVAC system elements
C403.14	Mechanical systems located outside of the <i>building thermal envelope</i>
C404	Service water heating
C405, except C405.3	Electrical power and lighting systems
C406.1.2	Additional renewable and load management credit requirements
C408	Maintenance information and system commissioning

a. Reference to a code section includes all the relative subsections except as indicated in the table.