



**AAMA CERTIFICATION PROGRAM**  
An FGIA Product Certification Program



**AUTHORIZATION FOR PRODUCT CERTIFICATION**

**Simonton Windows**  
1 Cochrane Dr.  
Pennsboro, WV 26415

**Attn: Tina Seese**

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

| SPECIFICATIONS  |   | RECORD OF PRODUCT TESTED |   |   |  |
|---|---|--------------------------|---|---|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-11<br>R-PG50-2870x1600 (113x63)-HS |   | AAMA 506-06              |   |   |  |
| COMPANY AND CODE  | Missile Level: D<br>Rating: +50/-50, 113x63<br>Wind Zone: 4 | CPD NO.                  | SERIES MODEL & PRODUCT DESCRIPTION  | MAXIMUM SIZE TESTED                               |  |
| Simonton Windows<br>Code: SIM                                   |   | 16040                    | 07-09/07-20 HS<br>(PVC)(XOX)(OG)<br>(0.090" PVB LAM GL)<br>(MODIF)(REINF)(ASTM) | <u>FRAME (mm)</u><br>2870 x 1600<br>(9'5" x 5'3") | <u>SASH (mm)</u><br>941 x 1492<br>(3'1" x 4'11") |

This Certification will expire **October 10, 2026 (extended from October 10, 2021 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

**PRI Construction Materials Technologies, LLC**

Report No: **SIMO-028-03-02**

Date of Report: **October 27, 2016**


Missile Impact Test & Report By:

**PRI Construction Materials Technologies, LLC**

Report No: **SIMO-028-03-01**

Date of Report: **October 27, 2016**

Evaluated for Certification: **June 14, 2021**

  
Associated Laboratories, Inc.

Authorized for Certification: **June 14, 2021**

  
Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)