



**AAMA CERTIFICATION PROGRAM**  
An FGIA Product Certification Program



**AUTHORIZATION FOR PRODUCT CERTIFICATION**

**Simonton Windows**  
1 Cochrane Dr.  
Pennsboro, WV 26415

**Attn: Tina Seese**

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.


SPECIFICATIONS		RECORD OF PRODUCT TESTED			
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11 R-PG50*-1524x1321 (60x52)-HS</b>	<b>AAMA 506</b>				
COMPANY AND CODE	Missile Level: C Rating: <b>+50/-50, 60x52</b> Wind Zone: 2	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
<b>Simonton Windows Code: SIM</b>	Rating above conforms to the requirements of: <b>ASTM E1886 and E1996</b>	<b>8419</b>	<b>42-19 HS (PVC)(XX)(OG) (INS 0.060" PVB LAM GL) (REINF)(ASTM)</b>	<b>FRAME (mm) 1524 x 1321 (5'0" x 4'4")</b>	<b>SASH (mm) 745 x 1238 (2'5" x 4'1")</b>

This Certification will expire **March 5, 2026 (extended from March 5, 2021 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:  
**Architectural Testing, Inc.**  
Report No: **B7592.01-501-47**  
Date of Report: **March 29, 2012**

Missile Impact Test & Report By:  
**Architectural Testing, Inc.**  
Report No: **B7591.01-501-47**  
Date of Reports: **March 26, 2012 (Revised June 11, 2012)**

Evaluated for Certification: **September 14, 2020**

  
Associated Laboratories, Inc.

Authorized for Certification: **September 14, 2020**

  
Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)