

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011367.01-R4
DATE: 12/19/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya
CODE: 661-1
REVISION DATE: 06/18/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan Ya Plastics Corporation USA 4016 Shadrack St. Houston, TX 77013	Series "In-Swing Transom" Vinyl Transom Window Configuration: OOO Glazing: IG-1/8" Tempered Glass/Laminate-1/8" Annealed Glass/0.090" PVB Interlayer/1/8" Annealed Glass Frame: W-3693mm(145.38") H-610mm(24") DLO: W-1159mm(45.63") H-534mm(21")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure = +80/-80 psf Water Penetration Resistance Test Pressure = 575 Pa (12.0 psf) Large Missile Impact Rated

Product Tested By: ETC Laboratories
Report No: ETC-08-209-21133.0
Expiration Date: August 31, 2032

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023