WINDOW & DOOR MANUFACTURERS ASSOCIATION
WDMA

Hallmark® Certificate of Conformance and License (CCL)

AMS, INC.
Administrative Management Systems, Inc.

Marvin
PO Box 100
401 State Ave N.
Warroad, MN 56763

Mfr ID: 407
For more Information visit www.amscert.com
Website: www.marvin.com
TEL: 218-386-1430

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
407-H-936.14	Elevate Inswing French Door XX 6080 IZ3	ASTM E-1996-14/ ASTM E-1886-13	DP +55/-55 psf, Missile D, Wind Zone 3	1803mm	2425mm	F9207.02-201-47 ; 32460.01-301-12-r0	2/24/2026	8/19/2016	2/2/2031
407-H-936.15	Elevate Inswing French Door IZ3	101/I.S.2/A440-11	Class LC-PG55; Size Tested 1803mm x 2425mm Type-SHD; DP +55/-55 psf; Water Test Press 400Pa (8.35psf); Can. Air Infil/Exfil. Level=A3	1803mm	2425mm	F9207.01-201-47 ; 32460.01-301-12-r0	2/24/2026	8/19/2016	2/2/2031

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: *John McFee, VP of Certification Programs, WDMA Hallmark*

By: *Lucas L. Wenzel, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com

ANAB
ANSI National Accreditation Board
ACCREDITED
ISO/IEC 17065
PRODUCT CERTIFICATION BODY
#0961