

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006716-R7
DATE: 09/18/2006
CERTIFICATION PROGRAM: Structural
COMPANY: Window Crafts.
CODE: 690-1
REVISION DATE: 11/26/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Window Craftsman 6031 Clark Center Avenue Sarasota, FL 34238	Series "75R Glass Sliding Doors" Aluminum Pocket/By-Pass/ Center-Meet Glass Door Configuration: XXXX Glazing: Monolithic (Tempered) Frame: W-4876mm(192") H-2438mm(96") Panel: W-1245mm(49") H-2407mm(94.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 AAMA/NWDA 101/I.S.2-97 TAS 202-94	Class CW-PG75 4876 x 2438 (192 x 96)-SD SD-C50 4876 x 2438 (192 x 96) SGD-C75 Design Pressure: ±3591 Pa (75 psf) Water Penetration Resistance Test Pressure: 540 Pa (11.25 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3220-1A/1B/W-1965
Expiration Date: February 28, 2030

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOP C-03/30/2023