

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009426-R3
DATE: 04/03/2008
CERTIFICATION PROGRAM: Structural
COMPANY: Provia
CODE: 1212-1
REVISION DATE: 07/06/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Provia, LLC 2150 State Route 39 Sugarcreek, OH 44681	"Prestige Vinyl Fixed Lite Models 7110 7111/8110/8111" Vinyl Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1500mm(60") H-1800mm(71") STP: Pos+7200 Pa (150.4psf) Neg-7200 Pa (150.4psf)

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05	FW-HC100 1500 x 1800 (60 x 71) Design Pressure: ±4800 Pa (100 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.0 psf)

Product Tested By: Air-Ins, Inc.
Report No: AI-02724-D
Expiration Date: June 30, 2024

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122