

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009502-R10
DATE: 07/01/2008
CERTIFICATION PROGRAM: Structural
COMPANY: YKK
CODE: 860-1
REVISION DATE: 06/26/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
YKK AP America, Inc. 101 Marietta Street NW, Suite 2100 Atlanta, GA 30303	StyleGuard® Casement Vinyl Window w/Stacking Mullion Configuration: X/X Glazing: IG-1/8" Annealed Glass/Laminate-1/8" Annealed Glass/0.090" Solutia Saflex PVB Interlayer/1/8" Annealed Glass Frame: W-1829mm(72") H-1575mm(62") Vent: W-842mm(33.16") H-1492mm(58.72")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: +50/-50 psf Large Missile Impact Rated Water Penetration Resistance Test Pressure: 359 Pa (7.5 psf)

Product Tested By: Hurricane Testing Laboratory, LLC
Report No: G231-0301-08/W-1954/W-2085
Expiration Date: **December 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

