

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013070.01-R4
DATE: 05/10/2017
CERTIFICATION PROGRAM: Structural
COMPANY: YKK AP
CODE: 860-1
REVISION DATE: 05/28/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
YKK AP America, Inc. 101 Marietta Street NW, Suite 2100 Atlanta, GA 30303	StyleView®/Precedence® Triple Casement Vinyl Window Configuration: XOX Glazing: Insulating Glass (Annealed) Frame: W-2743mm(108") H-2032mm(80") Vent: W-883mm(34.75") H-1981mm(78") DLO: W-775mm(30.5") H-1880mm(74")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG50 2743 x 2032 (108 x 80)-C Design Pressure: ±2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Intertek
Report No: G7591.01-550-44/F3782.05-550-44-R1/W-2179 /W-2190
Expiration Date: December 31, 2030

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023