WINDOW & DOOR MANUFACTURERS ASSOCIATION
WDMA

Hallmark® Certificate of Conformance and License (CCL)

AMS, INC.
Administrative Management Systems, Inc.

Pella Corporation
102 Main Street
Pella, IA 50219

Mfr ID: 411
For more Information visit www.amscert.com
Website: www.pella.com
TEL: 641-621-6096

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
411-H-1043.96	150 Series or Thermastar or Encompass Single Hung	101/I.S.2/A440-11	Class LC-PG35; Size Tested 2769mm x 1511mm* (109in x 59.5in*) Type-H; DP +35/-35 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A2	2769mm	1511mm	NCTL-310-6417-E0A1	9/11/2017	6/16/2027
411-H-1043.97	150 Series or Thermastar or Encompass Single Hung	101/I.S.2/A440-08	Class LC-PG35; Size Tested 2769mm x 1511mm* (109in x 59.5in*) Type-H; DP +35/-35 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A2	2769mm	1511mm	NCTL-310-6417-E0A1	9/11/2017	6/16/2027
411-H-1043.99	150 Series or Thermastar or Encompass Single Hung	101/I.S.2/A440-11	Class LC-PG35; Size Tested 2769mm x 1511mm* (109in x 59.5in*); Type-H; DP +35/-35 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A2	2769mm	1511mm	NCTL-310-6433-E0A1	9/11/2017	6/23/2027
411-H-1043.100	150 Series or Thermastar or Encompass Single Hung	101/I.S.2/A440-08	Class LC-PG35; Size Tested 2769mm x 1511mm* (109in x 59.5in)* Type-H; DP +35/-35 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A2	2769mm	1511mm	NCTL-310-6433-E0A1	9/11/2017	6/23/2027

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: *John McFee, VP of Certification Programs, WDMA Hallmark*

By: *Lucas L. Wenzel, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com