

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006738-R8
DATE: 09/29/2006
CERTIFICATION PROGRAM: Structural
COMPANY: ViWinTech
CODE: 583-1
REVISION DATE: 12/28/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ViWinTech Windows & Doors 2400 Irvin Cobb Drive Paducah, KY 42003	Series "Grand Vista 1100" Impact Rated Vinyl Sliding Glass Door Configuration: XXXO Glazing: IG-Exterior-1/8" Tempered Glass/ Interior-Laminate-1/8" Heat Strengthened Glass/ 0.090" Sentry Glas®Plus Interlayer/ 1/8" Heat Strengthened Glass Frame: W-4877mm(192") H-2438mm(96") Panel: W-1245mm(49") H-2362mm(93")

SPECIFICATION	PRODUCT RATING
ANSI/AAMA/NWDA 101/I.S.2-97 ASTM E1886-02/E1996-02 ASTM F842	SGD-C50 Design Pressure: +50/-50 psf Missile Level D-Wind Zone 4 FER-Passed

Product Tested By: Architectural Testing, Inc.
Report No: ATI-57345.06-122-44/57345.05-122-44
Expiration Date: **December 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com