

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006321-R9
DATE: 12/07/2005
CERTIFICATION PROGRAM: Structural
COMPANY: Regency
CODE: 750-1
REVISION DATE: 10/11/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Regency Plus, Inc. 2000 Locust Gap Highway Mount Carmel, PA 17851	Series "Tech 2000" Vinyl Casement Window Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-864mm(34") H-1905mm(75") Vent: W-813mm(32") H-1854mm(73)

SPECIFICATION	PRODUCT RATING
AAMA/NWWDA 101/I.S.2-97 ASTM F588	C-R45 34 x 75 Design Pressure: ±2155 Pa (45 psf) FER-Passed Water Penetration Resistance Test Pressure: 359 Pa (7.5 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-2747-2/W-1901/W-1979
Expiration Date: **December 31, 2027**

A handwritten signature in black ink, appearing to be 'Shirley', is written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122