

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI007050-R5
DATE: 03/27/2007
CERTIFICATION PROGRAM: Structural
COMPANY: Regency
CODE: 750-1
REVISION DATE: 09/09/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Regency Plus, Inc. 2000 Locust Gap Highway Mount Carmel, PA 17851	Series "Tech 5000 T Impact Mullion" Mulled Tilt Double Hungs w/Mulled Fixed Windows Configuration: OO//XX Glazing: IG-Interior-1/8" Annealed Glass/ Exterior-Laminate 1/8" Annealed Glass/0.090" DuPont Butacite/1/8" Annealed Glass Frame: W-2261mm(89") H-2438mm(96") DH: W-1118mm(44") H-1600mm(63") FW: W-1118mm(44") H-813mm(32)

SPECIFICATION	PRODUCT RATING
AAMA 450-00 ASTM E1886-05/E1996-04 TAS 201/202/203-94	Mulled Assembly Rating: R70 F/H-R70 2261 x 2438 (89 x 96) Wind Zone 4-Missile Level D Design Pressure: +70/-70 psf Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-10617-1/110-10617-3/110-10617-2/W-1901
Expiration Date: **February 28, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122