

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015092.01-R2
DATE: 08/31/2023
CERTIFICATION PROGRAM: Structural
COMPANY: YKK AP America
CODE: 860-1
REVISION DATE: 05/30/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
YKK AP America, Inc. 101 Marietta Street NW, Suite 2100 Atlanta, GA 30303	StyleView®/Precedence® Awning Vinyl Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-1511mm(59.5") H-902mm(35.5") Vent: W-1473mm(58") H-864mm(34")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG35 1511 x 902 (60 x 36)-AP Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Intertek, LLC
Report No: L2622.01-550-18/W-2179 /W-2190
Expiration Date: **December 31, 2030**

A handwritten signature in black ink, appearing to be "MD" or similar, written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

email: nami@namiinc.com

NOPC - 03/30/2023