

Hallmark® Certificate of Conformance and License (CCL)



Windsor Windows and Doors
900 South 19th Street
West Des Moines, IA 50265

Mfr ID: 453

For more Information visit www.amscert.com

Website: www.windsorwindows.com

TEL: 515-223-6660

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
453-H-009.00	Pinnacle Clad Sliding French Door	101/I.S.2/A440-11	Class R-PG40; Size Tested 2413mm x 2426mm Type-SD; DP +40/-40 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A2	2413mm	2426mm	ESP016942P	1/31/2016	6/10/2024
453-H-009.01	Pinnacle Clad Sliding French Door	101/I.S.2/A440-11	Class R-PG40; Size Tested 1803mm x 3035mm * Type-SD; DP +40/-40 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A2	1803mm	3035mm	ESP016749P	1/31/2016	5/15/2024
453-H-009.15	Pinnacle Clad Sliding French Door	101/I.S.2/A440-17	Class LC-PG50; Size Tested 2413 mm x 2502 mm Type-SD; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A2	2413 mm	2502 mm	ESP030029P	10/1/2019	9/19/2029
453-H-009.16	Pinnacle Clad Sliding French Door	101/I.S.2/A440-17	Class LC-PG50; Size Tested 4790 mm x 2502 mm Type-SD; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A2	4790 mm	2502 mm	ESP030029P.2 NAFS	10/1/2019	9/19/2029
453-H-009.19	Pinnacle Clad Sliding French Door	101/I.S.2/A440-17	Class LC-PG35; Size Tested 4791 mm x 2096 mm * Type-SD; DP +35/-35 psf; Water Test Press 260Pa (5.43psf); Can. Air Infil/Exfil. Level=A3	4791 mm	2096 mm	ESP0330703P.1	3/26/2020	3/4/2030
453-H-064.03	Pinnacle Clad Sliding Narrow Door	101/I.S.2/A440-17	Class LC-PG40; Size Tested 95.000 in x 95.500 in Type-SGD; DP +40/-40 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A2	95.000 in	95.500 in	ESP039017P.1	3/9/2023	12/15/2032

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Windsor Windows and Doors
900 South 19th Street
West Des Moines, IA 50265

Mfr ID: 453


For more Information visit www.amscert.com


Website: www.windsorwindows.com

TEL: 515-223-6660

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
--------------------	---------------------	-----------------	---------------	-------------	-------------	----------------------	-----------------	----------------

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  *John McFee, VP of Certification Programs, WDMA Hallmark*

By:  *Lucas L. Wenzel, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com