

Hallmark® Certificate of Conformance and License (CCL)




AMS, INC.
Administrative Management
Systems, Inc.


Marvin
PO Box 100
401 State Ave N.
401 State Ave N.
Warroad, MN 56763

Mfr ID: 407
For more Information visit www.amscert.com
Website: www.marvin.com
TEL: 218-386-1430

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
407-H-961.17	Ultimate Wood Double Hung Magnum IZ3 4848	101/I.S.2/A440-08	Class LC-PG50; Size tested 1356 x 2667mm (53 x 105 in)-H; Negative Design Pressure (DP) = 3120 Pa (65 psf)	1356mm	2667mm	B8461.01-201-47	6/22/2012	5/2/2022
407-H-961.19	Ultimate Wood Double Hung Magnum IZ3 4256 & 4848	ASTM E-1996-06 / ASTM E-1886-05	Wind Zone 3, Missile Level D, Cycle Pressure =50/-65 psf	1203mm	3073mm	B8463.01-201-47	6/22/2012	5/2/2022
407-H-961.20	Ultimate Wood Double Hung Magnum IZ3 4256 & 4848	ASTM E-1996-05 / ASTM E-1886-05	Wind Zone 3, Missile Level D, Cycle Pressure =50/-65 psf	1203mm	3073mm	B8463.01-201-47	6/22/2012	5/2/2022
407-H-961.21	Ultimate Wood Double Hung Magnum IZ3 4256 & 4848	ASTM E-1996-02 / ASTM E-1886-02	Wind Zone 3, Missile Level D, Cycle Pressure =50/-65 psf	1203mm	3073mm	B8463.01-201-47	6/22/2012	5/2/2022

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com