

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Windsor Windows and Doors
900 South 19th Street
West Des Moines, IA 50265

Mfr ID: 453


For more Information visit www.amscert.com

Website: www.windsorwindows.com

TEL: 515-223-6660

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
453-H-002.06	Pinnacle Clad Casement	101/I.S.2/A440-11	Class LC-PG50; Size Tested 914mm x 1829mm * Type-C; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A2	914mm	1829mm	ESP016941P.REV	1/31/2016	6/3/2024
453-H-002.12	Pinnacle Clad Casement	ASTM E-1996 12/ASTM E-1886-05	DP +50/-50 psf, Missile D, Wind Zone 3	914mm	1829mm	ESP016396P.ASTM	1/31/2016	5/26/2024
453-H-002.29	Pinnacle Clad Casement	101/I.S.2/A440-17	Class LC-PG65; Size Tested 762 mm x 1829 mm * Type-C; DP +65/-65 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A2	762 mm	1829 mm	ESP038164P	10/3/2022	5/4/2031
453-H-002.30	Pinnacle Clad Casement	ASTM E-1996-20 / ASTM E-1886-19	DP +65/-65 psf: Missile D, Wind Zone 4	762 mm	1829 mm	ESP038164P. ASTM C	10/3/2022	5/4/2031

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  *John McFee, VP of Certification Programs, WDMA Hallmark*

By:  *Lucas L. Wenzel, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com