

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013248.02-R4
DATE: 06/14/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Atrium
CODE: 2187-1
REVISION DATE: 11/25/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. 300 Welcome Center Blvd. Welcome, NC 27374	Series "311/312/378" Vinyl Sliding Glass Door w/Fin Installation Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-1828mm(72") H-2083mm(82") Panel: W-943mm(37.13") H-2024mm(79.69") DLO: W-934mm(36.75") H-2019mm(75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class R-PG35 1829 x 2083 (72 x 82)-SD SD-R35 1829 x 2083 (72 x 82) Design Pressure: ±1680 Pa (35 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)

Product Tested By: Architectural Testing, Inc.
Report No: D0986.01-801-47/W-2009
Expiration Date: **June 30, 2030**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023