

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013252-R4
DATE: 06/15/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Atrium
CODE: 1373-1
REVISION DATE: 09/05/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. 300 Welcome Center Blvd. Welcome, NC 27374	Series "388" Vinyl Sliding Glass Door w/Fin Installation Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-1829mm(72") H-2426mm(95.5") Panel: W-927mm(36.5") H-2353mm(92.63") DLO: W-805mm(31.69") H-2229mm(87.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class R-PG40 1829 x 2438 (72 x 96)-SD SD-R40 1829 x 2438 (72 x 96) Design Pressure: ±1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Architectural Testing, Inc.
Report No: D5179.01-801-47/W-2009
Expiration Date: February 28, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023