

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI005880.01-R8  
**DATE:** 12/10/2004  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Window Crafts.  
**CODE:** 690-1  
**REVISION DATE:** 04/07/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                        | PRODUCT DESCRIPTION                                                                                                                                                                                                                                                                                                |
|-------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Window Craftsmen</b><br><br><b>6031 Clark Center Avenue</b><br><br><b>Sarasota, FL 34238</b> | <b>Series "50" Aluminum Flange Impact</b><br><br><b>Frame Horizontal Sliding Window</b><br><br>Configuration: XX<br><br>Glazing: Laminate-3/16" Annealed<br>Glass/0.090"PVB Interlayer by Solutia/<br>3/16" Annealed Glass<br><br>Frame: W-1829mm(72")      H-1600mm(63")<br>Sash: W-940mm(37")      H-1549mm(61") |

| SPECIFICATION                                                                                                    | PRODUCT RATING                                                                                                                                    |
|------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b><br><b>AAMA/NWDA 101/I.S.2-97</b><br><b>ASTM E1886-02/13a/E1996-02/14a</b> | <b>Class CW-PG50 1829 x 1600 (72 x 63)-HS</b><br><b>HS-C50</b><br><b>Design Pressure: ±2400 Pa (50 psf)</b><br><b>Wind Zone 2-Missile Level D</b> |

Product Tested By: Certified Testing Laboratories  
Report No: CTLA-1294W/CTLA-1294W-1/W-1855/W-1965  
Expiration Date: October 31, 2030

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023