NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013032.02-R4**
DATE:	**02/29/2016**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Atrium**
CODE:	**1373-1**
REVISION DATE:	**06/26/2023**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. **300 Welcome Center Blvd.** **Welcome, NC 27374**	**Series "700/750" Mulled** **Vinyl Casement Window** **w/Transom & Finless Installation** Configuration: X/OO Glazing: Insulating Glass (Annealed) Frame: W-914mm(36") H-2743mm(108") Vent: W-864mm(34") H-1781mm(70.13") Fixed: W-914mm(36") H-914mm(36")

SPECIFICATION	PRODUCT RATING
AAMA 450-10 **AAMA/WDMA/CSA 101/I.S.2/A440-17** **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08**	**Applied Rating: LC35** **Mulled Fenestration Rating: LC35** **Overall Mulled Size: 914 x 2743 (36 x 108)** **Individual Tested Size:** **Class LC-PG60 914 x 1829 (36 x 72)-C** **Class LC-PG55 1829 x 1829 (72 x 72)-FW** **Design Pressure: ±1676 Pa (35 psf)** **Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf)**

Product Tested By: Architectural Testing, Inc.
Report No: E1443.01-801-47/E1438.01-801-47/A4449.01-801-47(Gateway)/W-1996
Expiration Date: **November 30, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com