

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013032.06-R4
DATE: 02/29/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Atrium
CODE: 1373-1
REVISION DATE: 01/03/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. 300 Welcome Center Blvd. Welcome, NC 27374	Series "700/750" Mulled Vinyl Casement Window w/Transom & Finless Installation Configuration: XX/OO Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72") H-2743mm(108") Vent: W-875mm(34.44") H-1791mm(70.25") Fixed: W-914mm(36") H-914mm(36")

SPECIFICATION	PRODUCT RATING
AAMA 450-10 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Applied Rating: LC35 Mulled Fenestration Rating: LC35 Overall Mulled Size: 1829 x 2743 (72 x 108) Individual Tested Size: Class LC-PG60 914 x 1829 (36 x 72)-C Class LC-PG55 1829 x 1829 (72 x 72)-FW Design Pressure: ±1676 Pa (35 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf)

Product Tested By: Architectural Testing, Inc.
Report No: E1442.01-801-47/E1438.01-801-47/E1449.01-801-47/W-2009
Expiration Date: **September 30, 2028**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC 03/30/2023