

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009728.02-R3
DATE: 10/05/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Shwinco
CODE: 1972-1
REVISION DATE: 06/16/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shwinco Architectural Products, LLC 171 Jet Services Way Dothan, AL 36303	Series "9800" Vinyl Side-Hinged Door Configuration: XX Glazing: IG-3/16" Tempered Glass/ 1/8" Annealed Glass/0.090" PVB Interlayer/ 1/8" Annealed Glass Frame: W-1880mm(74") H-2083mm(82") Panel: W-895mm(35.25") H-2021mm(79.56") DLO: W-619mm(24.38") H-1745mm(68.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 ASTM E1886-02/05/14A ASTM E1996-02/05/14A	Class R-PG50 1880 x 2083 (74 x 82)-SHD Design Pressure: ± 2400 Pa (± 50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Wind Zone 4-Missile Level D

Product Tested By: Intertek, PLC
Report No: L1417.01-550-44/NCTL 210-3539-1/W-1963
Expiration Date: September 30, 2028

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD" or similar, written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023