

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010243.01-R3
DATE: 10/05/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Shwinco
CODE: 1972-1
REVISION DATE: 06/16/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shwinco Architectural Products, LLC 171 Jet Services Way Dothan, AL 36303	Series "9800" Vinyl Side-Hinged Door Configuration: XX Glazing: IG-3/16" Tempered Glass/ 3/16" Heat Strengthened Glass/0.075" Vanceva Interlayer/3/16" Tempered Glass Frame: W-1880mm(74") H-2438mm(96") Panel: W-895mm(35.25") H-2376mm(93.56") DLO: W-619mm(24.38") H-2100mm(82.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 ASTM E1886-02/05/14A ASTM E1996-02/05/14A TAS 201/202/203-94	Class R-PG75 1880 x 2438 (74 x 96)-SHD Design Pressure: ± 3600 Pa (± 75 psf) Water Penetration Resistance Test Pressure: 540 Pa (11.28 psf) Wind Zone 4-Missile Level D Large Missile Impact Rated

Product Tested By: Intertek, PLC
Report No: L1417.02-550-44/NCTL 210-3587-1/W-1964
Expiration Date: August 31, 2028

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023