

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010720.01-R3
DATE: 08/08/2011
CERTIFICATION PROGRAM: Structural
COMPANY: ProVia LLC
CODE: 1212-1
REVISION DATE: 11/17/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ProVia LLC 2150 State Route 39 Sugarcreek, OH 44681	“Reinforced Vinyl Sliding Glass Door” Vinyl Sliding Door Configuration: XO Glazing: IG-Exterior-3/16" Tempered Glass/Interior-Laminate-1/8" Annealed Glass/0.090" Solutia Keepsafe PVB Interlayer/1/8" Annealed Glass Frame: W-2442mm(96.13") H-2438mm(96") Panel: W-1226mm(48.25") H-2324mm(91.5")

SPECIFICATION	PRODUCT RATING
ASTM E1886-02/05/E1996-02/05 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Design Pressure: ±2633 Pa (55 psf) Wind Zone 4-Missile Level D Class LC-PG55 2438 x 2438 (96 x 96)-SD SD-LC55 2438 x 2438 (96 x 96) Water Penetration Resistance Test Pressure: 395 Pa (8.25 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-13715-1/NCTL-110-13716-1
Expiration Date: April 30, 2027

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S. D.', is written over the signature line.

**NATIONAL ACCREDITATION &
MANAGEMENT INSTITUTE, INC**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com