

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI010720.03-R3  
**DATE:** 08/08/2011  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** ProVia LLC  
**CODE:** 1212-1  
**REVISION DATE:** 11/17/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>ProVia LLC</b> <b>2150 State Route 39</b> <b>Sugarcreek, OH 44681</b>	<b>“Reinforced Vinyl Sliding Glass Door”</b>  <b>Vinyl Sliding Door</b>  Configuration: XO  Glazing: Insulating Glass (Tempered)  Frame: W-2442mm(96.13")    H-2438mm(96") Panel: W-1226mm(48.25")    H-2324mm(91.5")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class CW-PG50 2438 x 2438 (96 x 96)-SD</b> <b>Design Pressure: ±2400 Pa (50 psf)</b> <b>Water Penetration Resistance Test Pressure: 395 Pa (8.25 psf)</b>

Product Tested By: National Certified Testing Laboratories, Inc.  
Report No: NCTL-110-13716-1  
Expiration Date: April 30, 2027

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

**NATIONAL ACCREDITATION &  
MANAGEMENT INSTITUTE, INC**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)