

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009781-R5
DATE: 01/29/2009
CERTIFICATION PROGRAM: Structural
COMPANY: ProVia Door
CODE: 1212-1
REVISION DATE: 01/10/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ProVia Door, Inc. 2150 State Route 39 Sugarcreek, OH 44681	Series "S-4200 Prestige Fixed Window" Vinyl Fixed Picture Window Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1270mm(50") H-2700mm(106")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05	FW-R75 1270 x 2700 (50 x 106) Design Pressure: ± 3600 Pa (± 75 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.0 psf)

Product Tested By: Air-Ins, Inc.
Report No: AI-03288-B1
Expiration Date: December 31, 2028

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC 03/30/2024